

875—93.10(89) Fixtures and fittings. All valves, pipe fittings, and appliances connected to a miniature boiler shall be equal to at least the minimal requirements of the construction or installation code, and rated for not less than the maximum allowable working pressure of the miniature boiler, and in no case will the rating be for less than 125 pounds.